

Assessing the technical feasibility of value chains for Reed based biofuels

ENEREED

Sustainable Energy Conversion from Reed Biomass



FH Burgenland

UNIVERSITY OF APPLIED SCIENCES

BRINGT BESONDERES ZUSAMMEN

Autors:

Jürgen Krail¹, Hannes Kitzler², Georg Beckmann³,
Helmut Plank¹, Christoph Pfeifer⁴ and Doris Rixrath¹

¹ University of Applied Sciences Burgenland. Pinkafeld, Austria

² Vienna University of Technology, Institute of Chemical Engineering. Vienna, Austria

³ Bureau for Mechanical and Energy Engineering. Vienna, Austria

Energy from reed biomass



Reed potentials in the Danube Region

Eastern Europe – Danube Delta:

- World's largest connected reed area
- Total area: 200,000ha

Central Europe – Fertő/Lake Neusiedl:

- Largest reed area in Central Europe
- Total area: 18,000ha




Energy from reed biomass

Key facts, current situation Fertő/Lake Neusiedl




- Extension reed belt: transnational Hungary (8,000ha) and Austria (10,000ha)
- Specific area yield: 5 – 23 t_{DM}/ha
- Total biomass potential for harvesting: 84,000t_{DM} (only Austrian territory)
- Nature conservation programs:
 - Fertő-Hanság Nemzeti Park, National Park Neusiedler See - Seewinkel
 - EU Natura 2000 – Landscape protection program
 - UNESCO – World heritage site
 - UNESCO – Ramsar convention on wetlands
- Management of resources:
 - Harvesting of reed for construction material (<10% of area)
 - No utilisation of fully grown reed for heating purposes
- Environmental impacts: deterioration of water quality, silting up of the lake

Reed belt expansion at Fertő/Lake Neusiedl National Park Areas



Light green area: mostly available for harvesting
Medium green area: national park, limited harvesting
Dark green areas: national park, no harvesting allowed




Führer, E.: Schnittpunkte der Schilfwirtschaft und des Naturschutzes am Neusiedler See, 2010

Nationalpark Neusiedler See - Seewinkel (Ed.): Nationalpark Neusiedlersee Seewinkel - Eckdaten 2009


Energy from reed biomass

Project overview



Energy from reed biomass

Investigated conversion paths



Fuel properties of reed

Comparison to different biofuels

	Unit	Reed	Woody biomass ^{2,}	Straw ^{2,}	Grain whole crops ^{2,}	Grain ^{2,}	Grasses ^{2,}
Ultimate analysis (dry mass)							
C- Content	% _{db}	45.48 [7]	↑↑ [113]	↔ [128]	↓ [60]	↓↓ [65]	↔ [128]
H- Content	% _{db}	5.84 [7]	↑↑ [76]	↑ [112]	↑↑ [57]	↑↑ [55]	↑↑ [158]
O- Content ^{1,}	% _{db}	40.52 [7]	↑ [-]	↓ [-]	↑↑ [-]	↑↑ [-]	↓↓ [-]
N- Content	% _{db}	0.47 [7]	↓↓ [133]	↓ [146]	↑↑ [66]	↑↑ [94]	↑ [204]
S- Content	% _{db}	0.07 [7]	↓ [119]	↑ [141]	↑↑ [62]	↑↑ [66]	↑↑ [173]
Cl- Content	% _{db}	0.15 [7]	↓↓ [122]	↑↑ [116]	↓ [56]	↓↓ [55]	↑↑ [116]
Proximate analysis (dry mass)							
Ash- Content	% _{db}	7.47 [7]	↓↓ [120]	↓ [145]	↓↓ [67]	↓↓ [64]	↓ [201]
Volatiles	% _{db}	76.98 [7]	↑ [86]	↓ [76]	↔ [52]	↑↑ [49]	↓↓ [159]
Lower heating value H _{u,p,db}	MJ/kg	16.38 [7]	↑↑ [115]	↓↓ [126]	↓↓ [58]	↓↓ [68]	↓↓ [218]
Ash melting behaviour							
Sintering temperature SIT	°C	1409 [7]	↓↓ [29]	↓↓ [48]	↓↓ [19]	↓↓ [13]	↓↓ [50]
Softening temperature SOT	°C	>1500 [7]	↓ [34]	↓↓ [59]	↓↓ [19]	↓↓ [14]	↓↓ [62]
↔ Basic value / equal to							
↓ ↑ Value lower (↓) / higher (↑) than basic value (basic value inside the typical range)							
↓↓ ↑↑ Value much lower (↓↓) / much higher (↑↑) than basic value (basic value outside of the typical range)							
^{1,} Calculated value as residual value (100% minus average content ash, C, H, N, K)							
^{2,} Analyses from (Hartmann, H. et al. 2000)							
[###] Number of analysed samples							

Harvesting technologies for reed

Conventional harvesting

vs.

Harvesting with increased degree of mechanisation



- Reaper-binder (bundles)
- Harvesting for construction purposes
- Higher demand of staff- resources (5 workers needed)
- + Lower ground pressure: 980 kg/m²
- + State-of-the Art technology



- Reaper-baler (round bales)
- Harvesting of reed for energy purposes
- + Lower demand of staff- resources (1-2 workers needed)
- Higher ground pressure: 1,220 kg/m²
- Prototype with development demand

–Harvesting at water depth < 40cm or frozen ground

Harvesting technologies for reed

Operational Characteristics

Conventional harvesting

vs.

Harvesting with increased degree of mechanisation



- Power of diesel engine: 118 kW
- Fuel consumption: 6.3 l/h
- Storage capacity (bundles): 1,850 kg
- Surface related yield (base): 5.5 t_{WB}/ha
- Duration of mowing route: 1.0 h/route
- Distance of mowing: 1,180 m
- Hourly harvesting output: 1.4 t_{WB}/h




- Power of diesel engine: 142 kW
- Fuel consumption: 10.0 l/h
- Storage capacity (bales): 760 kg
- Surface related yield (base): 6.2 t_{WB}/ha
- Duration of mowing route: 0.55 h/route
- Distance of mowing: 430 m
- Hourly harvesting output: 1.1 t_{WB}/h

Energy conversion small scale plant




Domestic heating - Pellet/wood chip boiler

- Pellet/woodchip boiler: HERZ firematic 80
 - Test procedure: ÖNORM EN 303-5 (1999)
 - Objective: Maximum heat power output under complete combustion conditions
- Tested biofuels:
 - Reed pellets
 - Wood pellets
 - Wood chips with bark



Energy conversion small scale plant

Domestic heating - Results of test runs



Energy conversion small scale plant


Domestic heating - Conclusion

- Fuels with high ash content can cause
 - shorter ash-discharging interval
 - unsteady combustion process (→ CO-peaks)
- Ash content is limiting factor in combustion → adaptations on the ash-discharging system
- When mass fraction of reed increases
 - lower heat power output
 - higher emissions
- Boiler efficiency: maximum 75 % mass portion of reed pellets combustion is recommended
- Emissions meet the requirements of the Austrian federal law “Combustion Plant Regulation (BGBl. II Nr. 312/2011)”

Energy conversion large scale plant




District heating – boiler with grate firing

- Woodchip boiler, nominal power 3MW
- Fuel transport system: pusher-floor transport
- Tested biofuel: wood chips, chopped reed
- Water content: wood chips 44%, reed 12.5%
- Fuel mixtures:
 - 100% wood chips (reference fuel)
 - 30% reed/70% wood chips (energy based)
 - 50% reed/50% wood chips (energy based)
 - 100% reed



Energy conversion large scale plant

District heating – Results of test runs



Energy conversion large scale plant

District heating - Conclusion

- Fuels with low volumetric energy density (chopped reed) can cause feeding problems in fuel supply
- Low energy density of chopped reed is limiting factor in fuel transport system → adaptations on the fuel feeding system
- When mass fraction of reed increases
 - thermal output constant, slightly decreasing
 - CO and NO_x – emissions decreases, SO₂ emissions increases
 - dust emissions decreases
- Emissions meet the requirements of the Austrian federal law “Waste Incineration Ordinance (BGBl. II Nr. 476/2010)”

Conclusion

- Potentials:
Large reed potentials are available for energetic utilisation
- Harvesting:
Further developments in technology are necessary for reliable harvesting machines
- Energetic utilisation:
Reed as alternative fuel can be used in a wide range of conversion possibilities

Co- combustion with wood is recommended; large scale plants lead to less problem in combustion; adaption of feeding/discharging system may be necessary

Measured emission meet the emission limits in both cases

Acknowledgment

Thanks to all our research partners!



Project Management
Industrial Conversion
Thermal Conversion Small Scale



Inst. f. Verfahrenstechnik,
Umwelttechnik und
Techn. Biowissenschaften

Thermal Conversion Large Scale

Technisches Büro für
Maschinenbau und Energietechnik
Dr. Georg Beckmann

Harvesting Technology

Jürgen Krail
University of Applied Sciences Burgenland
Steinamangerstrasse 21
A-7423 Pinkafeld
Austria

Tel.: +43-3357-45370-1328

Email: juergen.krail@fh-burgenland.at

The project ENEREED is funded by the Austrian "Klima- und Energiefonds" (carried out within the research promotion scheme "NEUE ENERGIEN 2020") and co funded by the Government of the Province of Burgenland, Lafarge Zementwerke GmbH and Herz Energietechnik GmbH.

